

## **Section 503 Venting of Appliances (Fuel Gas Code).**

**503.5.5 Size of chimneys.** The effective area of a chimney venting system serving listed appliances with draft hoods, Category I appliances, and other appliances listed for use with Type B vents shall be in accordance with IFGC section 504 or other approved engineering methods.

### **Exceptions:**

1. As an alternate method of sizing an individual chimney venting system for a single appliance with a draft hood, the effective areas of the vent connector and chimney flue shall be not less than the area of the appliance flue collar or draft hood outlet, nor greater than four times the draft hood outlet area.
2. As an alternate method for sizing a chimney venting system connected to two appliances with draft hoods, the effective area of the chimney flue shall be not less than the area of the larger draft hood outlet plus 50 percent of the area of the smaller draft hood outlet, nor greater than four times the smallest draft hood outlet area.

Where an incinerator is vented by a chimney serving other gas utilization appliance, the gas input to the incinerator shall not be included in calculating chimney size, provided the chimney flue diameter is not less than 1 inch (25.4 mm) larger in equivalent diameter than the diameter of the incinerator flue outlet.