

Board of Electricity
c/o Department of Labor and Industry
443 Lafayette Road North
Saint Paul, MN 55155-4344
dli.cclboards@state.mn.us

FINAL INTERPRETATION

Subject: Scope of National Electrical Code Article 547

Code Reference: Minnesota State Electrical Code, Chapter 1315

Submitted by: Minnesota Department of Labor and Industry
443 Lafayette Road North, Saint Paul, MN 55155

Approved by: Board of Electricity by Joseph Vespa, Chair

Date Received: April 7, 2010

Issue Date: April 13, 2010

Question: Does National Electrical Code Article 547 apply to premises where buildings, structures and areas are used for agricultural purposes but not animal confinement?

Answer: No.

Commentary: The Board considered this request for interpretation and made a determination regarding the final interpretation at the April 13, 2010, Board meeting. All persons present who wished to speak were given a full and fair opportunity to speak. The Board also considered written comments that were received before the meeting. As required by Minnesota Statutes, section 326B.127, subdivision 5, the Board will consider this Final Interpretation for adoption as part of the Minnesota Electrical Code.

Date: April 13, 2010



Joseph Vespa, Chair
Board of Electricity