

1.1 **Minnesota Plumbing Board**

1.2 **Adopted Exempt Permanent Rules Relating to the Uniform Plumbing Code**

1.3 **4714.0712 TESTING.**

1.4 *[For text of subpart 1, see Minnesota Rules]*

1.5 Subp. 2. **Section 712.** UPC section 712 is amended by adding subsections to read as
1.6 follows:

1.7 **712.4 Negative Test.** Concrete manholes and sewer lines shall be tested by negative pressure
1.8 in accordance with ASTM Standards C1214-19 and C1244-17 or the Hydrostatic Test
1.9 Method in section ~~1107.2.3(B)~~ 1107.2(B).

1.10 **712.5 Finished Plumbing.** After the plumbing fixtures have been set and their traps filled
1.11 with water, their connections shall be tested and proven gastight and watertight by plugging
1.12 the stack openings on the roof and the building drain where it leaves the building, and air
1.13 introduced into the system equal to the pressure of a 1-inch water column. Such pressure
1.14 shall remain constant for 15 minutes or the duration of the inspection without the introduction
1.15 of additional air.

1.16 **712.6 Test Plugs or Caps.** Test plugs or caps for roof terminals shall extend above or
1.17 outside the end of the vent pipe to provide a visible indication for removal after the test has
1.18 been completed.

1.19 **4714.1107 TESTING.**

1.20 Subpart 1. **Section 1107.1.** UPC section 1107.1 is amended to read as follows:

1.21 **1107.1 Testing Required.** Building storm drainage systems that are new and parts of existing
1.22 systems that have been altered, extended, or repaired shall be tested in accordance with
1.23 section 712 to disclose leaks and defects, except as provided in section ~~1107.2.3~~ 1107.2.
1.24 Any section of the building storm sewer that passes through contaminated soils or
1.25 contaminated water must be air tested in accordance with section 712.3.

2.1 Subp. 2. **Section ~~1107.2.3~~ 1107.2.** UPC ~~subsection 1107.2.3~~ is section 1107.2 and its
2.2 subsections are amended to read as follows:

2.3 **~~1107.2.3~~ 1107.2 Exceptions.**

2.4 (A) Testing is not required for:

2.5 (1) outside leaders;

2.6 (2) perforated or open drain tile; or

2.7 (3) portions of storm drainage system and sewers that are located more than ten feet
2.8 from buildings, more than ten feet from buried water lines, and more than 50 feet from
2.9 water wells, and that do not pass through soil or water identified as being contaminated.

2.10 (B) Building storm sewers shall be tested in accordance with section 712 or the
2.11 Hydrostatic Test Method from the City Engineers Association of Minnesota. The
2.12 Hydrostatic Test Method, provisions E2 and E3, as specified in Standard Utilities
2.13 Specifications for Watermain and Service Line Installation and Sanitary Sewer and
2.14 Storm Sewer Installation, written and published by the City Engineers Association of
2.15 Minnesota, 2018 edition, is incorporated by reference, is not subject to frequent change,
2.16 and is available in the office of the commissioner of labor and industry.

2.17 **4714.1601 GENERAL.**

2.18 *[For text of subpart 1, see State Register, volume 45, page 1007]*

2.19 Subp. 2. **Sections 1601.2 and 1601.3.** UPC sections 1601.2 and 1601.3 are deleted
2.20 in their entirety.

2.21 Subp. 3. **Section 1601.7.** UPC section 1601.7 is amended to read as follows:

2.22 **1601.7 Minimum Water Quality Requirements.** The minimum water quality for rainwater
2.23 catchment systems shall comply with the applicable water quality requirements for the

3.1 intended application as determined by the Authority Having Jurisdiction. Water quality for
3.2 nonpotable rainwater catchment systems shall comply with section 1602.9.6.

3.3 Subp. ~~2.~~ 4. **Section 1601.11.** UPC section 1601.11 is amended to read as follows:

3.4 **1601.11 Abandonment.** All rainwater catchment systems that are no longer in use and fail
3.5 to be maintained in accordance with section 1601.5 shall be considered abandoned.

3.6 Abandoned rainwater catchment systems are subject to sections 1601.11.1 and 1601.11.2.

3.7 **1601.11.1 General.** Every abandoned rainwater catchment system or part thereof
3.8 covered under the scope of this chapter, as amended in this code, shall be disconnected
3.9 from any remaining systems, drained, plugged, and capped per the requirements of this
3.10 code. Storm drainage systems of abandoned rainwater catchment systems must comply
3.11 with chapter 11, Storm Drainage, as amended.

3.12 **1601.11.2 Underground Tank.** Every underground water storage tank that has been
3.13 abandoned or otherwise discontinued from use in a rainwater catchment system covered
3.14 under the scope of this chapter, as amended in this code, shall be completely drained
3.15 and filled with earth, sand, gravel, or concrete or removed in a manner approved by
3.16 the administrative authority.

3.17 **4714.1602 NONPOTABLE RAINWATER CATCHMENT SYSTEMS.**

3.18 *[For text of subparts 1 to 8, see State Register, volume 45, page 1007]*

3.19 Subp. 9. **Subsection 1602.9.4.** UPC subsection 1602.9.4 is deleted in its entirety.

3.20 **4714.1701 REFERENCED STANDARDS.**

3.21 Subpart 1. UPC Table 1701.1 is modified to add the following:

STANDARD NUMBER	STANDARD TITLE	APPLICATION	REFERENCED SECTIONS
ASSE 1084-2018	Water Heaters with Temperature Limiting Capacity	Appliances	407.3, 409.4, 410.3
ASSE 1085-2018	Water Heaters for Emergency Equipment	Appliances	416.2
ASTM Standards C1214-19	Concrete Pipe Sewerlines by Negative Air Pressure (Vacuum) Test Method		712.4
ASTM Standards C1244-17	Concrete Sewer Manholes by the Negative Air Pressure (Vacuum) Test Prior to Backfill		712.4
CSA B125.3-2018	Plumbing Fittings	Fittings	409.4, 410.3
Hydrostatic Test Method (City Engineers Association of Minnesota) - 2018	Standard Utilities Specifications for Watermain and Service Line Installation and Sanitary Sewer and Storm Sewer Installation	Storm Drainage	1107.2.3(B) <u>1107.2(B)</u>

Subp. 2. UPC Table 1701.1 is modified by amending the following:

STANDARD NUMBER	STANDARD TITLE	APPLICATION	REFERENCED SECTIONS
ASME A112.3.1-2007	<u>Stainless Steel Drainage Systems for Sanitary DWV, Storm, and Vacuum Applications, Above- and Below-Ground</u>	<u>Piping</u>	<u>418.1, 423.1, Table 701.2, 705.7.2, 1102.1</u>
ASME A112.6.3-2001	<u>Floor and Trench Drains</u>	<u>Fixtures</u>	<u>418.1, 423.1</u>

5.1 5.2	ASME A112.6.9-2005	Siphonic Roof Drains	DWV Components	1106.2.3, 1106.2.8
5.3 5.4 5.5	ASME A112.18.1 - 2018 / CSA B125.1 - 2018	Plumbing Supply Fittings	Fittings	408.3, 417.1, 417.2, 417.3, 417.4, 417.6, 603.5.19
5.6 5.7 5.8	ASPE Standard 45	Siphonic Roof Drainage	Roof Drainage	1106.2.2 1106.2.5, 1106.2.9, 1106.3.1, 1106.3.2
5.9 5.10	ASSE 1023-2019	Electrically Heated or Cooled Water Dispensers	Appliances	417.6
5.11 5.12 5.13	<u>NSF 14-2016</u>	<u>Plastics Piping System Components and Related Materials</u>	<u>Miscellaneous</u>	<u>301.2.3, 604.1, 611.3</u>
5.14 5.15	<u>NSF 42-2015</u>	<u>Drinking Water Treatment Units - Aesthetic Effects</u>	<u>Appliances</u>	<u>611.1, 611.3</u>
5.16 5.17	<u>NSF 44-2015</u>	<u>Residential Cation Exchange Water Softeners</u>	<u>Appliances</u>	<u>611.1, 611.3</u>
5.18 5.19	<u>NSF 53-2015</u>	<u>Drinking Water Treatment Units - Health Effects</u>	<u>Appliances</u>	<u>611.1, 611.3</u>
5.20 5.21	<u>NSF 55-2016</u>	<u>Ultraviolet Microbiological Water Treatment Systems</u>	<u>Appliances</u>	<u>611.1, 611.3</u>
5.22 5.23	<u>NSF 58-2015</u>	<u>Reverse Osmosis Drinking Water Treatment Systems</u>	<u>Appliances</u>	<u>611.1, 611.2, 611.3</u>
5.24 5.25 5.26	<u>NSF 61-2016</u>	<u>Drinking Water System Components - Health Effects</u>	<u>Miscellaneous</u>	<u>415.1, 417.1, 604.1, 604.9, 606.1, 607.2, 608.2, 611.1.1</u>
5.27 5.28	<u>NSF 62-2015</u>	<u>Drinking Water Distillation Systems</u>	<u>Appliances</u>	<u>611.1, 611.3</u>

5.29 Unless amended above, all other entries in UPC Table 1701.1 are not amended.

5.30 *[For text of subparts 3 and 4, see Minnesota Rules]*

5.31 **EFFECTIVE DATE.** These amendments are effective December 17, 2021, or five working
5.32 days after publication of the amendments' notice of adoption in the State Register, whichever
5.33 is later.