

## **Section 901 General (Mechanical Code).**

**901.5 Unvented heaters and appliances.** Unvented room heaters, unvented infrared heaters, and unvented decorative appliances shall not be installed in any dwelling or occupancy.

**Exception:** Unvented infrared heaters may be installed when mechanical ventilation is provided to exhaust at least 4 cubic feet per minute (cfm) (0.0203 m<sup>3</sup>/s) per 1000 Btu/hr (0.292 kW) input and it is electrically interlocked with the heater. Makeup air shall be provided to the space to be heated.