

## IMC/IFGC TAG

### Meeting Notes

**Date:** Friday, March 16, 2018

**Meeting Location:** DLI Washington Room

### Call to order:

Chris Meier

### Attendance:

TAG Members present:

TAG Members absent:

Guests attending:

### Worksheet and Code Change Proposal Review:

#### 2018 IMC Section 501.4

The TAG reviewed a code change proposal to amend Minn. R. part 1346.0501, subp. 2, code section 501.4 to include new requirements for carbon monoxide monitoring for boiler rooms unless the boiler is less than 750,000 btu/hr, a service water heating boiler that is less than 500,000 btu/hr, or steam boiler less than 100,000 btu/hr. The fire alarm control unit should electronically supervise the carbon monoxide monitor. If there is no fire control unit, then the carbon monoxide monitor must alert an attended location in the building. The carbon monoxide monitor must be commercially rated or hard wired. The TAG consensus is to accept this proposal.

#### Minn. R. part 1346.5304, subp. 1, code table 304.1

The TAG reviewed a code change proposal to amend Minn. R. part 1346.5304, subp. 1, table 304.1, to add category III and category IV appliances to the table. The TAG consensus is to accept this proposal.

#### Minn. R. part 1346.5304, subp. 3, code section 304.6.2

The TAG reviewed a code change proposal to amend Minn. R. part 1346.5304, subp. 3, code section 304.6.2 to add a reference to code section 304.1, which includes the combustion air requirements.

#### 2018 IMC Section 502

The TAG reviewed a code change proposal to amend Minn. R. part 1346.0502 by adding requirements for carbon monoxide monitoring and ventilation of boiler and furnace rooms. The TAG consensus was to accept the proposed language but placing it in Minn. R. part 1346.5304, to further amend code section 304.1 and to add Minn. R. part 1346.0701 to amend code section 701.

#### 2018 IFGC Section 403.2.2

The TAG reviewed a code change proposal to amend 2018 IFGC section 403.2.2 on steel gas piping. The TAG consensus is to accept the code change proposal.

#### 2018 IMC Section 202

The TAG reviewed a code change proposal to amend the definition of “ready access.” The TAG consensus is to accept the code change proposal.

#### Minn. R. part 1346.0050

The TAG reviewed a proposal to amend Minn. R. part 1346.0050 to update the reference to NFPA 96 from the 2014 edition to the 2018 edition. The TAG consensus is to accept the code change proposal.

#### Minn. R. part 1346.0506, subp. 1, code section 506.3

The TAG reviewed a code change proposal to amend Minn. R. part 1346.0506, subp. 1, code section 506.3 to require ducts serving Type I hoods to be installed in accordance with NFPA 96 and ASHRAE 154. The TAG consensus is to accept the code change proposal.

#### Minn. R. part 1346.0506, subp. 3, code section 506.4.2

The TAG reviewed a code change proposal to amend Minn. R. part 1346.0506 subp. 3, code section 506.4.2 to include type II exhaust discharge locations. The TAG consensus is to accept the code change proposal.

#### Minn. R. part 1346.0507, subp. 1, code section 507.1.1

The TAG reviewed a code change proposal to amend Minn. R. 1346.0507, subp. 1, code section 507.1.1 to require hoods to be installed in accordance with NFPA 96 and ASHRAE 154. The TAG consensus is to accept the code change proposal.

#### Minn. R. part 1346.0508, subp. 1, code section 508.1

The TAG reviewed a code change proposal to amend Minn. R. part 1346.0508, subp. 1, code section 508.1 to require makeup air for commercial cooking appliances and type II applications. The TAG consensus is to accept the code change proposal.

#### Minn. R. part 1346.0202

The TAG reviewed a code change proposal to amend Minn. R. part 1346.0202 to amend the definition for commercial cooking appliance. The TAG consensus is to accept the code change proposal.

#### 2018 IMC Section 304.1.1 and 2018 IFGC Section 306.6

A code change proposal to amend 2018 IMC section 304.1.1 and 2018 IFGC section 306.6 to reference the OSHA standard for guards will be reviewed at the March 23, 2018 meeting.

Reviewed IMC Worksheet items #59 to #70

#### 2018 IMC Section 401.1

There are current Minnesota amendments to the 2012 IMC section 401.1. The TAG consensus is to renumber the Minnesota amendment for consistency with the IMC and keep the current amendment language.

#### 2018 IMC Section 404

There are current Minnesota amendments to the 2012 IMC section 404. 2018 IMC section 404 was tabled for review at the March 23, 2018 meeting.

#### 2018 IMC Section 501.2

There are current Minnesota amendments to the 2012 IMC section 501.2. The TAG consensus is to accept the 2018 IMC language and delete the current Minnesota amendments.

All references to “TAG consensus” indicates what the TAG will propose to the CCAC for their consideration.

### **Next Meeting:**

Date: March 23, 2018

Time: 8:30 AM

Location: DLI Washington Room

**Meeting Adjourned:** 3:56 PM

**Prepared by:** Chris Meier and Don Sivigny