



## Building Codes and Standards Unit - Plan Review Section

## PLAN REVIEW POLICY

PR-01 Smoke Resistant Construction 9/2015

Based on the 2015 Minnesota State Building Code

## Background:

The building code makes specific references to "construction capable of resisting the passage of smoke" (IBC Sec. 509.4.2). However, no definitive criterion has been provided to evaluate construction for compliance with these provisions for this section. As a result, a policy is needed to ensure consistent enforcement.

## Policy:

The following is considered meeting the requirements of IBC Sec. 509.4.2 (Incidental Use) Protection - Construction to resist the passage of smoke:

- 1. For penetrations of walls and for the termination of a wall to the floor or deck above, if the space around the penetrating items or the joint between the wall and the floor or deck above does not exceed 1½ inches, then the space is permitted to be filled with mineral wool, firesafing, or similar approved material. For annular spaces or joints in excess of 1½ inches, approved smoke sealant shall be used or the annual space or joint shall be reduced to not more than 1½ inch by approved wall materials and the annual space filled with mineral wool, fire-safing or similar approved materials.
- 2. Walls are permitted to terminate at the underside of a monolithic or suspended ceiling system where all of the following conditions are met:
  - (a) The ceiling system forms a continuous membrane.
  - (b) A smoke-tight joint is provided between the top of the smoke partition and the bottom of the suspended ceiling.
  - (c) Where the space above the ceiling is used as a plenum, return grilles from the hazardous area into the plenums are not permitted.
- 3. Air transfer openings shall not be permitted in the walls unless protected with an approved smoke damper. Smoke dampers are not required at penetrations by a ducted HVAC system.
- 4. Smoke-gasketing is not required so long as the door is relatively tight fitting.

Note: To be used in accordance with the attached, "Plan Review Policies"