

## Use of Service Entrance Cable (Type SE) for Interior Installations

### **What is the difference between an SE Cable and a USE Cable?**

National Electrical Code (NEC) Article 338 addresses Service Entrance cables, there are two types of service-entrance cables. Type SE having a flame-retardant, moisture-resistant covering and Type USE which is service entrance cable, identified for underground use, with a moisture-resistant covering, *but is not required to have a flame-retardant covering.*

All service-entrance cable is rated 600V and is listed in sizes 14 AWG and larger for copper and 12 AWG and larger for aluminum or copper-clad aluminum conductors.



The lettering “SE” on a cable indicates the cable outer jacket and the internal conductors are designed for above-ground installations and are listed for locations where the cable jacket and internal conductors are exposed to the sun in wet locations.

Type SE cable is made up of either: Type RHW, RHW-2, XHHW, XHHW-2, THWN or THWN-2 insulated conductors, and the outer jacket of the cable is flame-retardant. Type SE cable containing two or more conductors is permitted to have one conductor that is uninsulated.

Types USE and USE-2 cables are designed and listed for underground installations, including direct burial and available in both single-conductor and multi-conductor cables. Multi-conductor Type USE cable contains conductors with insulation equivalent to RHW or XHHW with the conductors rated at 90°C in a damp or dry locations but only 75°C for a wet application. Similarly, Type USE-2 cable contains conductors with insulation equivalent to RHW-2 or XHHW-2 and is rated at 90°C in a wet, damp or dry installation.

Type USE cable containing two or more conductors is permitted to have one conductor that is uninsulated.

(continued on next page)

## **Can SE Cable be installed in the interior of a building?**

Yes, Type SE cable is often used for interior wiring to supply heating and cooling equipment, appliance branch circuits and for feeders to subpanels. NEC 338.10 (B)(4) requires that when SE cable is installed as interior wiring it has to comply with the requirements of Part II of NEC Article 334, except for Section 334.80.

NEC Article 334, part II has the installation requirements for Non-Metallic Sheathed Cable (Type NM). However, the SE cable installations are not required to meet the rules of NEC 334.80, which covers the ampacity of Type NM cable installations.

The ampacity of conductors used in Type SE service-entrance cable for interior wiring but not installed within thermal insulation can be determined by using the 75°C column in NEC Table 310.15(B)(16) . Type SE cable is generally permitted to use the 75°C column because the insulation on the individual conductors in SE and SEU cable are Types RHW, RHW-2, XHHW, XHHW-2, THWN, or THWN-2.

If SE cable is installed in thermal insulation, the 60°C rating must be used. The non-metallic outer covering on the cable does not allow the heat from the conductors to be cooled by surrounding air. To determine the ampacity, use the 60°C rating column from NEC Table 310.15(B)(16).



If the ampacity must be adjusted or corrected according to NEC 310.15 the 90°C rating of the XHHW conductors inside the cable can be used as the starting point for any required adjustment. In the end, the conductor ampacity rating cannot be greater than the 60°C rating column from NEC Table 310.15(B)(16).