

ADVISORY COMMITTEE COMMENT FORM FOR PROPOSED CODE CHANGES

(This form must be submitted electronically)

Author/requestor: Jon Knudson

Email address: jon.knudson@ci.stpaul.mn.us

Telephone number: (651) 266-9062

Firm/Association affiliation, if any: MAPMO

1346, IMC #1

Proposed Code Change - Language

Please provide your proposed code change in strikeout/underline format. Provide the *specific* language you would like to see changed, with new words underlined and words to be deleted should be ~~stricken~~. Also, state whether the language contained in your proposal is from a code book or from an amendment currently found in Minnesota Rule. (You may provide the language (electronically) on a separate, attached sheet).

Remote heating and cooling coils shall be provided with service openings, large enough to permit inspection and maintenance. Access doors installed at service openings shall be suitable for the required duct construction. *This language should be added in section 306.

Proposed Code Change – Need and Reason

Please provide a thorough explanation of the need for this change and why this proposed code change is a reasonable change. During the rulemaking process, the Agency must defend the need and reasonableness of all its proposed changes. The Agency must submit evidence that it has considered all aspects of the proposal. (You may provide the need and reason (electronically) on a separate attached sheet).

Because all heating and cooling coils require maintenance. Currently, if these service openings aren't included in; the designer's specifications, already installed on the coil cabinet by the manufacturer, or labeled on the engineered prints, they're often not installed.

Proposed Code Change – Cost/Benefit Analysis

Please consider whether this proposed code change will increase/decrease costs or indicate that it will not have any cost implications and explain how it will not. If there is an increased cost, will this cost be offset somehow by a life safety or other benefit? If so, please explain. Are there any cost increases/decreases to enforce or comply with this proposed code change? If so, please explain. (You may provide the cost/benefit analysis (electronically) on a separate, attached sheet).

This code section would add an extra cost to the initial installation. However, since these coils must be maintained, the building owner would have to absorb this expense at a later date, probably at a greater cost.

Other Factors to Consider Related to Proposed Code Change

1. Is this proposed code change meant to:
 change language contained in a published code book? If so, list section(s).
no
 change language contained in an existing amendment in Minnesota Rule? If so, list Rule part(s).
no
 delete language contained in a published code book? If so, list section(s).
no
 delete language contained in an existing amendment in Minnesota Rule? If so, list Rule part(s).
no
 neither; this language will be new language, not found in the code book or in Minnesota Rule.
2. Is this proposed code change required by a Minnesota Statute or new legislation? If so, please provide the citation to the Statute or legislation.
no
3. Will this proposed code change impact other sections of a published code book or of an amendment in Minnesota Rule? If so, please list the affected sections or rule parts.
Yes, section 306 of the IFGC
4. Will this proposed code change impact other parts of the Minnesota State Building Code? If so, please list the affected parts of the Minnesota State Building Code.
no
5. Who are the parties affected or segments of industry affected by this proposed code change?
HVAC contractors, building owners
6. Can you think of other means or methods to achieve the purpose of the proposed code change? If so, please explain what they are and why your proposed change is the preferred method or means to achieve the desired result.
no
7. Are you aware of any federal requirement or regulation related to this proposed code change? If so, please list the regulation or requirement.
no