

Residential Code (1309) TAG

Meeting #12 Notes

Date: 4/22/2025

Meeting Location: DLI – Washington Room/Webex Event

Call to order: 9:02 am

Attendance:

TAG Members Attending:

Terence Olson (DLI), Jesse Szykulski (DLI), Kyle Thrapp, Steve Kartak, Lisa Hartwig, Greg Olson, Chris Rosival (DLI), Curtis (CJ) Johnson.

TAG Members Not Attending:

Nathan Weber

Guests Attending:

Amanda Spuckler (DLI), Mackenzie Johnson (DLI), Don Sivigny (DLI), Nick Erickson,

Code Change Proposal Review:

- The TAG reviewed a CCP for R325.9 to add requirements for the commissioning of forced air heating systems in dwelling units. The proposal was tabled for revision.
The TAG reviewed a CCP for R325.10 to clarify requirements for ducts in dwelling separation walls. The TAG consensus is to support the CCP.

Worksheet Review:

The TAG reviewed the worksheet corresponding to 2024 IRC sections from chapter 4, line item 43, section R408.1 to chapter 5, line item 15, section R505.2.2.

Chapter 4:

- Worksheet line 45, section R408.3, Under-Floor Space. The TAG tabled this section to verify there are no conflicts with mechanical provisions.
- Worksheet line 48, section R408.8, Under-Floor Vapor Retarder. The TAG consensus is to delete this section because it does not apply to Minnesota's climate zones.

Next Meeting:

Date: 5/6/2025

Time: 9:00 am.

Location: DLI – Washington Room

Meeting Adjourned: 11:54 pm.

Prepared by:

Terence Olson