

# Residential Code (1309) TAG

## Meeting #13 Notes

**Date:** 5/6/2025

**Meeting Location:** DLI – Washington Room/Webex Event

**Call to order:** 9:02 am

### **Attendance:**

#### TAG Members Attending:

Terence Olson (DLI), Jesse Szykulski (DLI), Kyle Thrapp, Steve Kartak, Lisa Hartwig, Greg Olson, Chris Rosival (DLI), Nathan Weber.

#### TAG Members Not Attending:

Curtis (CJ) Johnson

#### Guests Attending:

Amanda Spuckler (DLI), Mackenzie Johnson (DLI), Don Sivigny (DLI), Nick Erickson, Ron Nuttall.

### **Code Change Proposal Review:**

#### **Worksheet Review:**

The TAG reviewed the worksheet corresponding to 2024 IRC sections from chapter 5, line item 16, section R505.2.3 to chapter 6, line item 68, section R606.12.3.1.

#### Chapter 5:

- Worksheet line 35, Table R507.3.1, Minimum footing size for decks. The TAG consensus is to delete the current Minnesota amendment that modifies the table. The Structural TAG also recommended deleting the amendment.
- Worksheet line 45, Table R507.5(1), Maximum deck beam span. The TAG consensus is to delete the Minnesota amendment modifying the footnotes to this table. The Structural TAG also recommended deleting the amendment.
- Worksheet line 64, Table R507.6, Maximum deck joist spans. The TAG consensus is to delete the current Minnesota amendment that modifies the table. The Structural TAG also recommended deleting the amendment.
- Worksheet line 67, Table R507.7, Maximum joist spacing for wood decking. The TAG consensus is to delete the current Minnesota amendment that modifies the table. The Structural TAG also recommended deleting the amendment.
- Worksheet line 70, Table R507.9.1.3(1), Deck ledger connection to band joist. The TAG consensus is to delete the MN. The Structural TAG also recommended deleting the amendment.

#### Chapter 6:

- Worksheet line 10, Minnesota Rules, part 1309.0602, subpart 1, Maximum allowable length of wood wall studs exposed to wind speeds of 115 MPH or less. The TAG consensus is to delete the Minnesota amendment modifying Table 602.3.1 of the 2018 IRC. The Structural TAG also recommended deleting the amendment.
- Worksheet line 32, section R602.10.6, Construction of methods ABW, PFH, PFG, CS-PF, BV-WSP. The TAG members tabled discussion of this section.

### **Next Meeting:**

Date: 5/20/2025

Time: 9:00 a.m.

Location: DLI – Washington Room

**Meeting Adjourned:** 11:44 p.m.

**Prepared by:**

Terence Olson