

## Residential Code (1309) TAG

### Meeting #14 Notes

**Date:** 5/20/2025

**Meeting Location:** DLI – Washington Room/Webex Event

**Call to order:** 9:01 a.m.

### **Attendance:**

#### **TAG Members Attending:**

Terence Olson (DLI), Jesse Szykulski (DLI), Kyle Thrapp, Steve Kartak, Lisa Hartwig, Greg Olson, Chris Rosival (DLI), Nathan Weber, Curtis (CJ) Johnson.

#### **TAG Members Not Attending:**

#### **Guests Attending:**

Amanda Spuckler (DLI), Mackenzie Johnson (DLI), Don Sivigny (DLI), Nick Erickson, Greg Metz (DLI), Eric Fowler, Mike Pulte.

#### **Guests Attending on-line:**

Brian Baughman, Chad Payment (DLI), David McDonald, Ed Lisinski, Eric Fowler, Ethan Culver, Faith Mainor, John Nelsen, Joshua Harmon, Michael Johnson, Michael Rhodes, Michelle Hunt, Nicholas Haeg, Peter Kulczyk, Scott Anderson, Shawn Wetterlin, Steve Shold.

### **Code Change Proposal Review:**

- The TAG reviewed a CCP to add new section R318.2.1 that requires footings for landings at egress doors. The TAG consensus is to accept the CCP.
- The TAG reviewed a CCP for R325.9 that requires the testing of dwelling forced air heating systems. The TAG consensus is to accept the CCP.
- The TAG reviewed a CCP that adds new section R333 that requires EV charging infrastructure be provided in new dwellings. The TAG consensus is not to accept the code change proposal.
- The TAG reviewed a CCP for R403.1.4.1 modifying the requirements for frost protection of footings footing frost protection. The TAG consensus is to accept the CCP.
- The TAG reviewed a CCP for R507.3.3 that modifies the requirements for frost protection of deck footings. The TAG consensus is to accept the CCP.

### **Next Meeting:**

Date: 6/17/2025

Time: 9:00 a.m.

Location: DLI – Washington Room

**Meeting Adjourned:** 11:58 a.m.

**Prepared by:**

Terence Olson